

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1483:149 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

DESIGN: Model "Genesis" "EST" MG1M and *MG1M-RM sync modules. Unit is an electronic circuit mounted on a printed wiring board and enclosed in a plastic case. Units are intended for use with *listee's Model "EST" *MG1 series single gang strobe lights (CSFM Listing No. 7125-1483:148) and Models *MG1H, *MG1-P, *MG1-HO horns or Models *MG1-HV15, -HV30, -HV60, -HV75 or *-HV10 horn strobes (CSFM Listing No. 7125-1483:147). Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Edwards, model number, electrical/candela rating and UL label.

APPROVAL: Listed as sync modules for use with separately listed compatible fire alarm control units. For indoor use only.

XLf: 7300-1591:201

*Rev. 05-23-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**